

DEKRA Industrial SAS
ACT. VALORISATION DU PATRIMOINE RAA
36 avenue Jean Mermoz
CS 58812
69355 LYON CEDEX 08
Tel : 04.72.78.13.98
Fax : 04.72.78.44.04

Our Ref. : 52399451 / 1

Contract No. 2017 1969 5182 – Version 1

TEST CERTIFICATE

We, the undersigned **DEKRA Industrial SAS**, located at 36 Avenue Jean Mermoz, CS 58812 – 69355 Lyon Cedex 08 FRANCE certify that :

The “DiaSafe® Guard Straight” self-supporting aluminium guardrail, weighted with two stabilising weights of 12.5 kg each at the rear below each of the four uprights (i.e. a total of 25 kg applied at the end of each strut) and resting at the front against a lower stop symbolising a parapet, in the configuration with three spans (the central span of a length of 2.50 m and each of the two lateral spans of a length of 1.05 m) as described on the drawing entitled « Straight free-standing H 1100 mm DiaSafe® Guard Straight » dated 16/03/2017

distributed by the company DIADEM, APP Kft. – Fehervari ut 75. – H9028 GYÖR - HUNGARY

has had the following tests performed upon it:

- Tests for compliance with protocols and static loading requirements for a Class A guardrail (see NB), defined by the NF EN 13374 standard of July 2013– paragraph 7.4

The aforementioned static tests produced satisfactory results with regard to the criteria defined in standard NF EN 13374 of July 2013.

DEKRA Industrial SAS Test Report reference: 52076382 / 5

NB: maximum angle of inclination of the working surface: 10°.

Lyon, 10 May 2017

Gilles Béraud
Transaction Manager

