

DEKRA Industrial SAS
Activité Valorisation du Patrimoine
36 avenue Jean Mermoz – CS 58812
69355 LYON CEDEX 08
Phone: + 33 (0)4.72.78.13.98
Fax: + 33 (0)4.72.78.44.04

Our ref.: 52925544 / 1

TEST CERTIFICATE

We the undersigned **DEKRA Industrial SAS**, sis 36 Avenue Jean Mermoz, CS 58812 - 69355 LYON Cedex 08, certify that:

The " DiaSafe® Guard Straight " self-supporting aluminium guardrail, with an aluminium lower rail, ballasted by three stabilising counterweights of 12.5 kg each at the rear in line with each of the two end uprights (i.e. a total of 37.5 kg applied at the end of each of the external struts), and stabilising counterweights of 12.5 kg each at the rear in line with the central upright (i.e. a total of 25 kg applied at the end of the middle strut), resting at the front against a bottom stop symbolizing a parapet in the configuration with two spans of length 1.50 m each as described on the drawing entitled " DiaSafe® Guard Straight " of 18/10/2017

distributed by the company DIADEM, APP Kft. – Fehervari ut 75. – H9028 GYÖR - HUNGARY

has been subjected to the following tests:

- Static tests of compliance with the protocols and the requirements defined by the NF EN ISO 14122-3 standard of March 2017 – Paragraph 8.2

The static tests outlined above produced satisfactory results in relation to the criteria defined in the NF EN ISO 14122-3 standard of March 2017.

DEKRA Industrial SAS Test Report reference: 5253744A / 18

Lyon, 19 March 2019

Gilles BERAUD
Account Manager

